


ENERGY AUDIT REPORT

of

RAHUL COLLEGE OF EDUCATION

Navghar Raod, Bhayander (East), Thane 401 105




Year: 2020-21

Prepared by:

ENRICH CONSULTANTS

Yashashree, 26, Nirmal Bag Society,
Near Mukhtangan English School, Parvati, Pune 411009
Phone: 09890444795 Email: enrichcons@gmail.com



REGISTRATION CERTIFICATES


Regn. No. EA-8192 No.2942


National Productivity Council
(National Certifying Agency)
PROVISIONAL CERTIFICATE

This is to certify that Mr. / Ms. Achyut Yashavant Mehendale
son / daughter of Mr. Yashavant
has passed the National Certification Examination for Energy Auditors in April - 2007, conducted on behalf of the Bureau of Energy Efficiency, Ministry of Power, Government of India.

He / She is qualified as Certified Energy Manager as well as Certified Energy Auditor.
He / She shall be entitled to practice as Energy Auditor under the Energy Conservation Act 2001, subject to the fulfillment of qualifications for the Accredited Energy Auditor and issue of certificate of Accreditation by the Bureau of Energy Efficiency under the said Act.


This certificate is valid till the issuance of an official certificate by the Bureau of Energy Efficiency.

Place : Chennai, India 
Controller of Examination

Date : 10th August 2007

BEE AUDITOR CERTIFICATE

MAHARASHTRA ENERGY DEVELOPMENT AGENCY
An ISO 9001 : 2000 Reg. no. HQ 91 / 2462


Maharashtra Energy Development Agency
(Government of Maharashtra Institution)
Aundh Road, Opposite Spicer College Road, Near Commissionerate of Animal Husbandary,
Aundh, Pune, Maharashtra - 411067
Ph No: 020-35006450
Email: eee@mahaurja.com, Web: www.mahaurja.com

ECN/2021-22/CR-14/1577 22nd April, 2021

**CERTIFICATE OF REGISTRATION
FOR CLASS 'A'**


We hereby certify that, the firm having following particulars is registered with **MAHARASHTRA ENERGY DEVELOPMENT AGENCY (MEDA)** under given category as "Energy Planner & Energy Auditor" in Maharashtra for Energy Conservation Programme of MEDA.

Name and Address of the firm : M/s Enrich Consultants
Yashashree, Plot No. 26, Nirmal Bag Society,
Near Muktangan English School, Parvati,
Pune - 411009.


Registration Category : Empanelled Consultant for Energy Conservation Programme for Class 'A'

Registration Number : MEDA/ECN/2021-22/Class A/EA-03

- Energy Conservation Programme intends to identify areas where wasteful use of energy occurs and to evaluate the scope for Energy Conservation and take concrete steps to achieve the evaluated energy savings.
- MEDA reserves the right to visit at any time without giving prior information to verify quarterly activities performed by the firm and canceling the registration, if the information is found incorrect.
- This empanelment is valid till **21st April, 2023** from the date of registration, to carry out energy audits under the Energy Conservation Programme
- The Director General, MEDA reserves the right to cancel the registration at any time without assigning any reasons thereof.


General Manager (EC)

MEDA EMPANELMENT CERTIFICATE



ENRICH CONSULTANTS

Yashashree, 26, Nirmal Bag Society,
Near Mukhtangan English School, Parvati, Pune 411 009
Tel: 09890444795 Email: enrichcons@gmail.com

Ref: EC/RCOE/20-21/01

Date: 12/7/2021

CERTIFICATE

This is to certify that we have conducted Energy Audit at Rahul College of Education, Bhayander (East) Thane 401 105, in the Academic year 2020-21.

The College has adopted following Energy Efficient Practices:

- Usage of Energy Efficient LED Fittings
- Usage of Energy Efficient BEE STAR Rated equipment
- Maximum usage of Day Lighting

We appreciate the support of Management, involvement of faculty members and students in the process of making the Campus Energy Efficient.

For Enrich Consultants,



A Y Mehendale,
Certified Energy Auditor
EA-8192




INDEX

Sr. No	Particulars	Page No
I	Acknowledgement	5
II	Executive Summary	6
III	Abbreviations	7
1	Introduction	8
2	Study of Connected Load	9
3	Study of Present Energy Consumption	10
4	Carbon Foot Printing	11
5	Study of Usage of Alternate Energy	12
6	Study of LED Lighting	13

ACKNOWLEDGEMENT

We Enrich Consultants, Pune, express our sincere gratitude to the management of Rahul College of Education, Bhayander (East) Thane 401 105, for awarding us the assignment of Energy Audit of their Campus for the Year: 2020-21.

We are thankful to all Staff members for helping us during the field study.



EXECUTIVE SUMMARY

1. **Rahul College of Education, Bhayander**, consumes Energy in the form of **Electrical Energy**; used for various Electrical Equipment.

2. Present Energy Consumption & CO₂ Emission:

No	Parameter/ Value	Energy Consumed, kWh	CO ₂ Emissions, MT
1	Total	15338	13.80
2	Maximum	2778	2.50
3	Minimum	878	0.79
4	Average	1278.17	1.15

3. Energy Conservation Measures Implemented:

- Usage of Energy Efficient LED fittings
- Maximum Usage of Day Lighting

4. Usage of Alternate Energy:

- The College has yet to install Roof Top Solar PV Plant.

5. Usage of LED Lighting:

- The Total LED Lighting Load of the College is **0.892 kW**.
- The Total Lighting Demand of the College is **5.472 kW**.
- The percentage of LED Lighting to Total Lighting Load is **16.30 %**.

6. Assumption:


1. **1 kWh** of Electrical Energy releases **0.9 Kg of CO₂** into atmosphere

7. Reference:

- For CO₂ Emissions: www.tatapower.com

ABBREVIATIONS

LED	:	Light Emitting Diode
BEE	:	Bureau of Energy Efficiency
FTL	:	Fluorescent Tube Light
CFL	:	Compact Fluorescent Light
PV	:	Photo Voltaic
Kg	:	Kilo Gram
kWh	:	kilo-Watt Hour
CO ₂	:	Carbon Di Oxide
MT	:	Metric Ton



CHAPTER-I INTRODUCTION

1.1 Objectives:

1. To study Connected Load of the College.
2. To study Present Energy Consumption
3. To Study the present CO₂ emissions
4. To study usage of Renewable Energy
5. To study usage of LED Lighting

1.2 Table No 1: General Details of the College:

No	Head	Particulars
1	Name of College	Rahul College of Education
2	Address	Navghar Road, Bhayander (East) Thane 401 105
3	Affiliation	University of Mumbai


CHAPTER-II STUDY OF CONNECTED LOAD

The major contributors to the connected load of the College include:

Table No 2: Study of Equipment wise Connected Load:

No	Equipment	Qty	Load, W/unit	Load, kW
1	40 W FTL Fitting	93	40	3.72
2	18 W CFL Fitting	43	20	0.86
3	20 W LED Fitting	23	20	0.46
4	16 W LED Fitting	27	16	0.43
5	Ceiling Fan	77	65	5.005
6	1 TR AC	4	1275	5.10
7	1.5 TR AC	21	1912.5	40.16
8	P C	44	150	6.6
9	Printer	3	175	0.53
10	Other Equipment	7	350	2.45
11	Total			65.31

Chart No 1: Study of Connected Load:





CHAPTER-III STUDY OF PRESENT ENERGY CONSUMPTION

In this chapter, we present the analysis of Electrical Energy Consumption

Table No 3: Electrical Energy Consumption Analysis- 2020-21:

No	Month	Energy Consumed, kWh
1	Jun-20	878
2	Jul-20	878
3	Aug-20	2778
4	Sep-20	1005
5	Oct-20	1136
6	Nov-20	1237
7	Dec-20	1139
8	Jan-21	1069
9	Feb-21	1398
10	Mar-21	1448
11	Apr-21	1036
12	May-21	1336
13	Total	15338
14	Maximum	2778
15	Minimum	878
16	Average	1278.17

Chart No 2: Variation in Monthly Energy Consumption:



CHAPTER-IV CARBON FOOT PRINTING


A Carbon Foot print is defined as the Total Greenhouse Gas emissions, emitted due to various activities. **Basis for computation of CO₂ Emissions:**

- 1 Unit (kWh) of Electrical Energy releases 0.9 Kg of CO₂ into atmosphere

Table No 4: Month wise CO₂ Emissions:

No	Month	Energy Consumed, kWh	CO ₂ Emissions, MT
1	Jun-20	878	0.79
2	Jul-20	878	0.79
3	Aug-20	2778	2.50
4	Sep-20	1005	0.90
5	Oct-20	1136	1.02
6	Nov-20	1237	1.11
7	Dec-20	1139	1.03
8	Jan-21	1069	0.96
9	Feb-21	1398	1.26
10	Mar-21	1448	1.30
11	Apr-21	1036	0.93
12	May-21	1336	1.20
13	Total	15338	13.80
14	Maximum	2778	2.50
15	Minimum	878	0.79
16	Average	1278.17	1.15


Chart No 3: Month wise CO₂ Emissions:



CHAPTER-V

STUDY OF USAGE OF ALTERNATE ENERGY

The College has yet to install Solar PV Plant



CHAPTER VI STUDY OF USAGE OF LED LIGHTING

In this chapter, we compute the percentage of usage of LEDs to Total Lighting Load.

Table No 5: Percentage of Usage of LED Lighting to Total Lighting Load:

No	Particulars	Value	Unit
1	No of 40 W FTL Fittings	93	Nos
2	Load of 40 W FTL Fitting	40	W/unit
3	Total Load of 40 W FTL Fitting	3.72	kW
4	No of 18 W CGL Fittings	43	Nos
5	Load of 18 W CGL Fitting	20	W/unit
6	Total Load of 18 W CGL Fitting	0.86	kW
7	No of 20 W LED Fittings	23	Nos
8	Load of 20 W LED Fitting	20	W/unit
9	Total Load of 20 W LED Fitting	0.46	kW
10	No of 16 W LED Fittings	27	Nos
11	Load of 16 W LED Fitting	16	W/unit
12	Total Load of 16 W LED Fitting	0.432	kW
13	Total LED Lighting Load= 9+12	0.892	kW
14	Total Lighting Load= 3+6+9+12	5.472	kW
15	% of LED to Total Lighting Load= $13 \times 100 / 14$	16.30	%